



Table of Contents for Standard Detail Drawings and Acronyms

May 2012

Drawing Number	Title
OV-1	WATER MAIN CUT-IN
OV-2	STANDARD PIT DIMENSIONS FOR HOT TAPS 3" AND LARGER
OV-3	THRUST BLOCK BEARING AREA
OV-4	PIPE RESTRAINED LENGTH
OV-5A	MAXIMUM DEFLECTION FOR DUCTILE IRON PIPE
OV-5B	MAXIMUM DEFLECTION FOR PVC PIPE
OV-6	UTILITY CROSSING
OV-7	UTILITY CROSSING UNDER EXISTING WATER MAIN
OV-8	TRANSITION SLEEVE
OV-9	TRENCH DETAIL
OV-10	VALVE BOX INSTALLATION AND OPERATING NUT EXTENSION
OV-11	LOCATING WIRE FOR WATER MAINS AND SERVICES
OV-12A	FIRE HYDRANT INSTALLATION WATER MAIN IN STREET
OV-12B	HYDRANT CLEARANCE GUIDELINES
OV-13	4" BLOW OFF ASSEMBLY (TYPICAL)
OV-14	1" COMBINATION AIR/VACUUM VALVE
OV-15A	1"-2" WATER SERVICE INSTALLATION
OV-15B	1" RESIDENTIAL METERED WATER SERVICE
OV-16A	2" METER WITH BY-PASS – PLAN VIEW
OV-16B	2" METER WITH BY-PASS – FRONT VIEW
OV-17A	3" TO 6" METER WITH BY-PASS – PLAN VIEW
OV-17B	3" TO 6" METER WITH BY-PASS – FRONT VIEW
OV-18A	REDUCED PRESSURE BACKFLOW PREVENTER 1" TO 2"
OV-18B	DOUBLE CHECK DETECTOR OR RP PRINCIPLE DETECTOR 3" AND LARGER