


**NOTES:**

1. SEE THE ORANGE VALE WATER COMPANY CONSTRUCTION SPECIFICATIONS AND THE PROJECT WATER NOTES FOR REQUIREMENTS.
2. ALL PIPE DIMENSIONS SHALL INCLUDE MIN 6" DISTANCE BETWEEN PIPE BELL AND TRENCH WALL.
3. PLACE INITIAL SAND BACKFILL TO TOP OF PIPE. SPRAY WITH WATER TO COMPACT. THEN PLACE INITIAL SAND TOP OF PIPE. SPRAY WITH WATER TO COMPACT. AFTER SPRAYING WITH WATER, USE MECHANICAL COMPACTION METHODS IF NEEDED.
4. COORDINATE COMPACTION TESTS WITH INSPECTOR.
5. JETTING WILL NOT BE ALLOWED FOR COMPACTION OF BACKFILL OR PIPE BEDDING MATERIAL.
6. IN UNPAVED AREAS, PIPE BEDDING MATERIAL, AND INITIAL BACKFILL MATERIALS SHALL BE COMPACTED THE SAME AS IN PAVED AREAS.
7. ALL COMPACTION CALLOUTS SHALL BE MODIFIED PROCTOR (ASTM D-1557).
8. STREET REPAIRS AND TRENCH BACKFILL UNDER PAVED ROADS SHALL COMPLY WITH COUNTY OF SACRAMENTO CONSTRUCTION STANDARDS OR OTHER ENTITY HAVING JURISDICTION.

**ORANGE VALE WATER COMPANY**



**TRENCH DETAIL**

SCALE: NONE  
DATE: 05/12

**OV-9**