



- ① REINFORCED CONCRETE UTILITY BOX (CHRISTY N30)
- ② REINFORCED CONCRETE COVER WITH READER DOOR LID AND A 1-7/8" PRE-CAST HOLE FOR RADIO READ PENETRATION (CHRISTY N30 COVER)
- ③ 1" WATER METER (100 CU. FT. REGISTER) SUPPLIED BY OVWC
- ④ CONCRETE BLOCKS SHALL BE PLACED ALONG ENTIRE PERIMETER TO SUPPORT METER BOX.
- ⑤ 1"x18" COPPER SETTER WITH LOCKWING ANGLE METER STOP FULL PORTED BALL TYPE AND ANGLE METER DUAL CHECK VALVE (MUELLER B-2404-2)
- ⑥ 1" CURB STOP WITH TEFLON COATED BALL
- ⑦ BRONZE ADAPTER (AS REQUIRED)
- ⑧ 1" x 36" BRASS NIPPLE, WITH BRASS CAP

NOTE:

- 1. ALL METALLIC PIPES AND FITTINGS SHALL BE ENCASED WITH 8 MIL PLASTIC SO THAT NO SOIL IS IN CONTACT WITH THE PIPES AND FITTINGS
- 2. METER BOX SHALL NOT BE LOCATED IN SIDEWALKS OR DRIVEWAYS.

ORANGE VALE WATER COMPANY		
	1" RESIDENTIAL METERED WATER SERVICE	
	SCALE: NONE DATE: 05/12	OV-15B