


NOTES:

1. FITTINGS SHALL BE DUCTILE IRON, AWWA C110 OR C153.
2. PROVIDE 6 INCHES SAND BEDDING. BACKFILL WITH SAND TO 12 INCHES ABOVE THE TOP OF PIPE. COMPACT TO 90% RELATIVE COMPACTION.
3. THESE JOINTS MAY BE FLANGED, RESTRAINED MECHANICAL JOINT WITH OVWC APPROVED RESTRAINING DEVICES, OR OVWC APPROVED EQUAL.
4. ALL BURIED METAL SHALL BE ENCASED WITH 8 MIL POLYETHYLENE SO THAT NO SOIL IS IN CONTACT WITH METAL.

ORANGE VALE WATER COMPANY



TYPICAL 4" BLOW OFF ASSEMBLY

SCALE: NONE
DATE: 05/12

OV-13